

STATEMENT OF BASIS
TOWN OF CARBONADO
NPDES PERMIT NO. WA0020834

The purpose of this Statement of Basis is to explain the need to modify the Permit to clarify the wastewater effluent Biochemical Oxygen Demand Five-Day (BOD₅) and Total Suspended Solids (TSS) correct sampling types for the Town of Carbonado Wastewater Treatment Plant.

I. GENERAL INFORMATION

- A. Permittee: Town of Carbonado
 P.O. Box 91
 Carbondado, Washington 98396
- B. Discharge Locations: Carbon River
 Latitude: 47° 04' 44" N
 Longitude: 123° 03' 31" W

II. REQUEST FOR MODIFICATION:

In S2.A of the existing permit requires wastewater effluent BOD₅ and TSS sample types to be a grab samples. The correct sampling types for BOD₅ and TSS are 24-hour composite sample.

The modification made to the permit was the change in S2.A wastewater effluent BOD₅ and TSS sample types from grab to 24-hour composite samples.

This Statement of Basis will serve as an amendment to the Fact Sheet and Permit.